

4P 1200V 32A



1 Waterproof Plug

- 2 IP66NW Ingress Protection
- 3 Sealing Plug
- 4 OFF
- 5 LOCK
- 6 Standard
- 7 Brand
- 8 Type
- 9 ON
- 10 Knob

BYT-32 BYT-32 with MC4







Accessories


Application

ZBENY BYT Series DC Isolator Switch in plastic enclosure is applied 1~20KW Residential or Commercial Photovoltaic system, placed between photovoltage modules and inverters. Arcing time less than 3ms, that keep solar system more safe To ensure its stability and long service life, our products are made by components with optimum quality. Max voltage up to 1200V DC It holds a safe lead among similar products.

Feature

- IP66, UV Resistance
- Arcing Time < 3ms
- Earth Terminal
- IEC60947-3, AS60947.3
- 2 Pole, 4 Poles Available(Single | Double String)
- DC-PV2 / DC-21B: 32A up to 1200VDC

Appearance Introduction





Parameter

Electrical Characteristic					
Туре		BYT-32, BYT-32M1, BYT-32M2, BYT.1-32, BYT.2-32			
Function		Isolator, Control			
Standard		IEC60947-3, AS60947.3			
Utilization category		DC-PV2/DC-21B			
Pole		4P			
Rated frequency		DC			
Rated operational voltage	e (U_)	600V, 800V, 1000V, 1200V			
Rated operational current	t (<i>I</i> _)	See the next page			
Rated insulation voltage ((<i>U</i> _i)	1200V			
Conventional free air ther	mal current(I _{th})	11			
Conventional enclosed th	ermal current(I _{the})	Same as I_{e}			
Rated short-time withstar	nd current (I _{cw})	1kA,1s (4, 4B); 1.7kA, 1s (2H)			
Rated short-time making	capacity (I _{cm})	1.7kA(4, 4B); 3kA(2H)			
Rated conditional short-c	(6/7	3kA			
Rated impulsed withstand	d voltage (U_{imp})	8.0kV			
Overvoltage category		II			
Suitability for isolation		Yes			
Polarity		No polarity, "+" and "-" polarities could be interchanged.			
Service Life/Cycle Oper	ation				
Mechanical		15000			
Electrical		1000			
Installation Environmer	nt				
Ingress Protection	nclsoure	IP66			
	witch body	IP20			
Storage Temperature		-50°C ~ +90°C			
Operation Temperature		-40°C ~ +85°C			
Mounting Type		Vertically or horizontally			
Pollution degree		3			



Breathing Valve





Remarks:

 ${\sf ZJBENY\,DC\,Isolator\,has\,a\,breathing\,valve\,already, to\,avoid\,the\,condensation\,issue.}$

Identification	Rating data	Rating data			
Switch, unenclosed - catalogue number (with DC-PV2 rating)	BYT.1-32, BYT.2-	BYT.1-32, BYT.2-32			
Specific dedicated individual enclosure - catalogue number (with minimum IP56NW rating)	BYT-32 IP66NV	BYT-32 IP66NW			
Assembly of switch and specific dedicated individual enclosure - catalogue number	/	/			
I_{th} rated thermal current, unenclosed, at 40°C shade ambient air temperature	32 amps	32 amps			
I_{the} rated thermal current, indoors, at 40°C shade ambient air temperature, in a specific dedicated enclosure	32 amps	32 amps			
<i>I</i> _{the} rated thermal current <u>outdoors</u> at 40°C shade ambient air temperature <u>without solar</u> <u>effects in</u> a specific dedicated enclosure rated IP66NW	32 amps				
I_{the} solar current value outdoors at 60°C shade ambient air temperature (see D.8.3.11,table D3), with solar effects in a specific dedicated enclosure rated IP66NW	29 amps				
	UeIe; DC-PV2ratedratedoperationaloperationalvoltagecurrentDC VoltsAmps	<i>I_(make)</i> and <i>I_{c(break)}</i> DC-PV2 4 x <i>I</i> e Amps			
	300 32	128			
	500 32	128			
4-pole 2 pole in series (<u>1/_2/</u>)	600 13	52			
4	800 13	36			
	1000 9	36			
	1200 9	36			
	300 32	128			
2 polo	500 32	128			
2-pole 4 pole in series (<u>1/_2/_3/_4/</u>)	600 32	128			
4B	800 32	128			
	1000 32	128			
	1200 32	128			



Contacts wiring diagram	300V	600V	800V	1000V	1200V	Poles in series	Number of Strings	Type Number
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	32A	32A	13A	9A	9A	2	2	4
	40A	40A	1	1	1	4	1	2Н
	32A	32A	32A	32A	32A	4	1	4B
	32A	32A	32A	32A	32A	4	1	4S

Wiring Diagram for Rated operational voltage Ue (V) & Rated operational current le (A)

Switching Configurations

Туре	4-pole	2-pole 4 Paralleled Poles	4-pole with Input and Output bottom	4-pole with Input on top Output bottom
1	4	2Н	4B	4S
Contacts Wiring graph	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$
Switching example				

Bridging links installation




* Warning: Verify that all connections (including bridging link connections) are suitable for the rated current, prepared to ensure only conductive parts are clamped and tightened to the manufacturers required torque before energization.



Terminals / connection

Туре		BYT-32, BYT-32M1, BYT-32M2,		
		BYT.1-32, BYT.2-32		
Number of poles		4-pole		
Terminal designation, main circuit		1; 3; 5; 2; 4; 6; 7; 8		
Type of terminal, main circuit		Screw terminal		
Rated cross section area, main circuit		4.0-16mm ²		
Type of onductor		4-16mm ² (Rigid: Solid or Stranded)		
		4-10mm ² (Flexible)		
Number of conductors per terminal		1		
Required preparation of the conductor		Yes		
Stripping length (mm), main circuit		8mm		
Tightening torque (M4), main circuit		Min: 1.2Nm		
		Max: 1.8Nm		


IP Rating



Remarks:

ZJBENY DC Isolator can be installed in any direction, but must do well performance for waterproof.

Dimensions(mm)





Data according to AS60947-3: 2018

Main Contacts		Туре	BYT-32	Appendix B5
Rated thermal current I_{the}		А	32	Making &
Rated insulation voltage U _i		V	1200	Breaking
Distance of contacts (per pole)	mm	8	5x	
Rated operational current le (DC-PV2)			operations	
1 pole	300V	А	25	100
1 –	400V	А	10	40
_	500V	А	8	32
_1/	600V	А	8	32
_	800V	А	3	12
_	1000V	А	2	8
4-pole	500V	А	32	128
2 pole in series	600V	А	32	128
	700V	А	13	52
_1/_2/	800V	А	13	52
_	900V	А	9	36
	1000V	А	9	36
_	1200V	А	9	36
2-pole	500V	А	40	160
4 parallel poles — 2H	600V	А	40	160
	700V	А	1	1
$\begin{array}{c} 1 \\ 3 \\ 4 \\ \end{array}$	800V	А	1	1
	900V	А	1	1
_	1000V	А	1	1
_	1200V	А	1	1
2-pole	500V	А	32	128
4 pole in series 4B	600V	А	32	128
	700V	А	32	128
	800V	A	32	128
-	900V	A	32	32
_	1000V	A	32	32
—	1200V	А	32	32